



BLINDSIDE MEMBRANE FIELD SHEET WITH FABRIC TOWARD CONCRETE POUR OR SHOTCRETE WHEN NOT IN THE WATER TABLE - CONSULT POLYGUARD IF IN THE WATER TABLE, BUTT UP FLUSH TO STUD PLATE

DETAIL SEALANT PW OR LM-95 APPLIED AND TOOLED FOR ADHESIVE BOND TO MINIMUM 90 MILS CONTINUOUS OVER SOIL NAIL, STUD PLATE, MINIMUM 3" ONTO EACH NELSON STUD, AND MINIMUM 6" ONTO BLINDSIDE MEMBRANE FABRIC PREPARED WITH 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF / GAL

DETAIL SEALANT PW OR LM-95 APPLIED AND TOOLED FOR ADHESIVE BOND TO MINIMUM 90 MILS CONTINUOUS OVER ALL FABRIC TAPE EXPOSED EDGES AND BLINDSIDE MEMBRANE FABRIC, PREPARE BOTH AREAS TO BE COVERED WITH 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF / GAL

EXISTING SOIL NAIL (BY OTHERS) TO REMAIN, CLEAN AND DRY IN PREPARATION FOR POLYGUARD OVERLAY WATERPROOFING MATERIALS

EXISTING STUD PLATE AND NELSON STUDS (BY OTHERS) TO REMAIN, CLEAN AND DRY IN PREPARATION FOR POLYGUARD OVERLAY WATERPROOFING MATERIALS

FABRIC TAPE APPLIED OVER (SELECTED) LM-95 LIQUID MEMBRANE OR DETAIL SEALANT PW ON SOIL NAIL, STUD PLATE, AND BLINDSIDE MEMBRANE; EXTEND A MINIMUM 6" ONTO BLINDSIDE MEMBRANE FABRIC PREPARED WITH 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF / GAL

POLYGUARD POLYFLOW 15 DRAINBOARD WITH FABRIC FACING TOWARD SHOTCRETE STRUCTURAL WALL

APPROVED RETENTION SYSTEM - BY OTHERS

**BS5**

**SECTION @ BLINDSIDE MEMBRANE - SOIL NAIL / STUD PLATE CONDITION**

©POLYGUARD PRODUCTS, INC.

SOME MATERIALS SEPARATED FOR CLARITY

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us.	NOT TO SCALE
	EFFECTIVE DATE: 03/05/2021
	SUPERCEDES: 04/07/2020