


To properly insulate through a roof top duct support; lift duct off of support, insulate duct through the support, install Alumaguard through the support and add an additional layer of Alumaguard 6" wide on the bottom and both sides at the point of contact with the support system. If duct cannot be lifted off supports, see Detail Drawing 2 "Insulating duct on supports"

6" STRIP OF ALUMAGUARD ON BOTTOM AND SIDES AT POINT OF CONTACT WITH DUCT SUPPORT SYSTEM



SECTION @ INSULATING DUCT AT SUPPORTS DETAIL 1

POLYGUARD PRODUCTS, INC. 2011

(NOT TO SCALE)

Polyguard Products, Inc.
 P.O. Box 755 - Ennis, TX 75119
 Phone: 214-515-5000 Fax: 972-875-9425
 Web Site - www.polyguardproducts.com
 x:\u\s\in\dl\undersell\2007\Mechanical\Alumaguard\81\insulatingductatsupportsdetail1

Polyguard

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us.